

ASPEN COVE FIRE HYDRANT INSPECTION REPORT

Date _____ Inspected 1 thru 10 on 4-28-17 and 12 thru 17 on 10-19-17

#1	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	No	yes	ok	yes	125	yes	Leaking from underground while running
#2	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	No	yes	ok	yes	60	yes	
#3	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	no	yes	ok	yes	80	yes	
#4	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	no	yes	ok	yes	70	yes	
#5	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	no	yes	ok	yes	130	yes	
#6	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	no	yes	ok	yes	120	yes	Leaking from underground while running
#7	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	no	yes	ok	yes	105	yes	Leaking from underground in front of hydrant and from hydrant base washer while running
#8	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	no	yes	ok	yes	120	yes	Leaks from underground while running
#9	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	Fair	yes	ok	yes	135	yes	
#10	Paint OK	Pole marker	Gate Valve	Opens/ Closes	Pressure	Drains	Comments
	fair	yes	ok	no	150	yes	Repaired 10-23-17. Replaced valve seat and main rubber. Cleared brush away from it.

	Paint	Pole	Gate	Opens/			Comments
#11	OK	marker	Valve	Closes	Pressure	Drains	
	yes	yes	ok	no	160	yes	Repaired 10-23-17. Replaced valve seat and main rubber
#12	OK	marker	Valve	Closes	Pressure	Drains	Comments
	yes	yes	ok	yes	170	yes	
#13	OK	marker	Valve	Closes	Pressure	Drains	Comments
	yes	yes	ok	no	155	yes	Got it to close eventually. May need attention next year
#14	OK	marker	Valve	Closes	Pressure	Drains	Comments
	Fair	yes	ok	yes	150	yes	rubber washer at base of hydrant leaks while running
#15	OK	marker	Valve	Closes	Pressure	Drains	Comments
	yes	yes	ok	yes	160	yes	Gate valve in front of hydrant was close and is open
#16	OK	marker	Valve	Closes	Pressure	Drains	Comments
	yes	yes	ok	yes	130	yes	
#16	OK	marker	Valve	Closes	Pressure	Drains	Comments
	yes	yes	ok	yes	160	yes	Leak from underground while running